Section 2.3. Interior Finishing, Furnishing and Decorative Materials

2.3.1. **General**

2.3.1.1. Interior Finish

 The interior finish material that forms part of the interior surface of a floor, wall, partition or ceiling shall conform to the NBC(AE).

2.3.1.2. Movable Partitions and Screens

 Movable partitions or screens, including acoustical screens, shall have a flune-spread rating not greater than that required for the interior finish of the area in which they are located.

2.3.1.3. Decorative Materials

 Decorative materials on walls or ceilings shall have a flame-spread rating not greater than that required for the interior finish of the space in which they are located.

2.3.1.4. Interconnected Floor Spaces

 Combustible contents in interconnected floor spaces in which the ceiling is more than 8 m above the floor, shall not exceed the limit specified in Subsection 3.2.8. of Division B of the NBC(AE).

National Fire Code - 2023 Alberta Edition

Division B 2-5

2.3.2.1. Division B

2.3.2. Flame Resistance

2.3.2.1. Drapes, Curtains and Decorative Materials

- 1) Drapes, curtains and other decorative materials, including textiles and films, used in buildings shall conform to CAN/ULC-S109, "Standard Method for Flame Tests of Flame-Resistant Fabrics and Films," when such drapes, curtains and other decorative materials are used in
 - a) any assembly occupancy or Group B, Division 1 detention occupancy,
 - b) any lobby or exit, or
 - c) any open floor areas exceeding 500 m² in any business and personal services, mercantile or industrial occupancy, except where the floor area is divided into fire compartments not exceeding 500 m² in area and separated from the remainder of the floor area by fire separations having at least a 1 h fire-resistance rating.